

HTI Birr Courthouse Windows

Window repair: Howley Hayes Cooney Report 'There is an ad hoc collection of windows from different periods across all four facades. Three original timber sashes with an elegant, lambs tongue profile remain on the front of the building, and these should be retained and repaired. replacement windows with an ovolo profile have been installed elsewhere, and the large spoked windows in the courtroom have been replaced with poorly detailed single glazed modern replicas. Secondary acrylic screens have been installed to the internal side of these windows as a measure to prevent heat loss. Tooled limestone sills are still in place throughout.'



- Original window - lambs tongue profile.
- Replacement Sash - Lambs tongue profile
- Replacement window - Ovolo profile.
- Modern replacement.

Survey of existing front facade windows



2021_0917 – Windows repaired and refitted by Core Joinery





Entrance lobby with upper historic sash repaired, replacment lower section with matching glazing detail





8/4 sash window and large courtroom sash – final coat of paint

